

Multi-view Clustering Analyses for District Heating Substations

Shahrooz Abghari¹^a, Veselka Boeva¹, Jens Brage² and Håkan Grahn¹^b

¹Department of Computer Science, Blekinge Institute of Technology, Karlskrona, Sweden

²NODA Intelligent Systems AB, Karlshamn, Sweden

Keywords: Data Mining, Multi-view Clustering, Multi-layer Clustering, Time Series, District Heating Substation.

Abstract: In this study, we propose a multi-view clustering approach for mining and analysing multi-view network datasets. The proposed approach is applied and evaluated on a real-world scenario for monitoring and analysing district heating (DH) network conditions and identifying substations with sub-optimal behaviour. Initially, geographical locations of the substations are used to build an approximate graph representation of the DH network. Two different analyses can further be applied in this context: step-wise and parallel-wise multi-view clustering. The step-wise analysis is meant to sequentially consider and analyse substations with respect to a few different views. At each step, a new clustering solution is built on top of the one generated by the previously considered view, which organizes the substations in a hierarchical structure that can be used for multi-view comparisons. The parallel-wise analysis on the other hand, provides the opportunity to analyse substations with regards to two different views in parallel. Such analysis is aimed to represent and identify the relationships between substations by organizing them in a bipartite graph and analysing the substations' distribution with respect to each view. The proposed data analysis and visualization approach arms domain experts with means for analysing DH network performance. In addition, it will facilitate the identification of substations with deviating operational behaviour based on comparative analysis with their closely located neighbours.

1 INTRODUCTION

District heating (DH) systems utilize hot water and heat produced at a *production unit* for a number of *consumer units*, i.e., buildings, in a limited geographical area through a *distribution network*. This part of the system is referred to as the *primary* side. The consumer unit itself consists of a heat exchanger, a circulation network, and radiators for the rooms, which are considered as the secondary side. The primary and secondary sides are connected together through a substation, which is responsible for adjusting the pressure and the temperature of the supply water suitable for the consumer unit.

In the DH domain, energy companies need to address several conflicting goals such as satisfying consumers' heat demand including domestic hot water (DHW) while minimizing production and distribution costs. Such complexity demands fault detection and root cause analysis techniques for identification of deviating behaviours and faults. Undetected faults

can lead to underlying problems, which in return can increase the maintenance cost and reduce the consumers' satisfaction. When it comes to monitoring of a DH network there are different features and characteristics that one needs to consider. Domain experts often analyse substations individually or in a group with regard to one specific feature or a combination of features. While this provides useful information for the whole network it does not take into account the location of the substations along the distribution network and their neighbouring substations automatically. In other words, the operational behaviours of the DH substations need to be assessed jointly with surrounding substations within a limited geographical distance. Due to the nature of the data and the fact that different data representations can be used, the process of monitoring and identifying faults and deviating behaviours of the DH system and substations can be treated as a multi-view data analysis problem.

Multi-view datasets consist of multiple data representations or views, where each one may contain several features (Deepak and Anna, 2019). Multi-view learning is a semi-supervised approach with the goal

^a <https://orcid.org/0000-0002-3010-8798>

^b <https://orcid.org/0000-0001-9947-1088>

to obtain better performance by applying the relationship between different views rather than one to facilitate the difficulty of a learning problem (Blum and Mitchell, 1998; Ando and Zhang, 2007; Xu et al., 2013). Due to availability of inexpensive unlabeled data in many application domains, multi-view unsupervised learning and specifically multi-view clustering (MVC) attract great attention (Deepak and Anna, 2019). The goal of multi-view clustering is to find groups of similar objects based on multiple data representations.

We propose a multi-view clustering analysis approach for mining network datasets with multiple representations. The proposed approach is used for monitoring a DH network and identifying DH substations with sub-optimal operational behavior. We initially use geographical location of substations to divide them into groups of similar substations based on their distance and location. In that way, we are able to: 1) group the substations (network nodes) based on their location and distance, 2) build an approximate graph representation of the DH network, and 3) order the substations using information about the DH network structure and the average supply water temperature for a specific period. Two different types of analyses can then be applied in this scenario: i) step-wise clustering to sequentially consider and analyse substations with respect to a few different views; ii) parallel-wise clustering to analyse substations with regards to two different views in parallel.

2 RELATED WORK

MVC clustering algorithms have been proposed based on different frameworks and approaches such as k -means variants (Bickel and Scheffer, 2004; Cai et al., 2013; Jiang et al., 2016), matrix factorization (Liu et al., 2013; Zong et al., 2017), spectral methods (Kumar and Daumé, 2011; Wang et al., 2013) and exemplar-based approaches (Meng et al., 2015; Wang et al., 2015).

Bickel and Scheffers (Bickel and Scheffer, 2004) proposed extensions to different partitioning and agglomerative MVC algorithm. That study can probably be recognized as one of the earliest works where an extension of k -means algorithm for two-view document clustering is proposed. In another study (Cai et al., 2013), the authors developed a large-scale MVC algorithm based on k -means with a strategy for weighting views. The proposed method is based on the $\ell_{2,1}$ norm, where the ℓ_1 norm is enforced on data points to reduce the effect of outlier data and the ℓ_2 norm is applied on the features. In a recent study,

Jiang et al. (Jiang et al., 2016) proposed an extension of k -means with a strategy for weighting both views and features. Each feature within each view is given bi-level weights to express its importance both at the feature level and the view level.

Liu et al. (Liu et al., 2013) proposed an MVC algorithm based on joint non-negative matrix factorization (NMF). The developed algorithm incorporates separate matrix factorizations to achieve similar coefficient matrices and further meaningful and comparable clustering solution across all views. In a recent study, Zong et al. (Zong et al., 2017) proposed an extension of NMF for MVC that is based on manifold regularization. The proposed framework maintains the locally geometrical structure of multi-view data by including consensus manifold and consensus coefficient matrix with multi-manifold regularization.

Kumar and Daumé (Kumar and Daumé, 2011) proposed an MVC algorithm for two-view data by combining co-training and spectral clustering. The approach is based on learning the clustering in one view to *label* the data and modify the similarity matrix of the other view. The modification of the similarity matrices are performed using discriminative eigenvectors. Wang et al. (Wang et al., 2013) proposed a variant of spectral MVC method for situations where there are disagreements between data views using Pareto optimization as a means of relaxation of the agreement assumption.

Meng et al. (Meng et al., 2015) proposed an MVC algorithm based on affinity propagation (AP) for scientific journal clustering where the similarity matrices of the two views (text view and citations view) are integrated as a weighted average similarity matrix. In another study, Wang et al. (Wang et al., 2015) proposed a variant of AP where an MVC model consists of two components for measuring 1) the within-view clustering quality and 2) the explicit clustering consistency across different views.

Fault detection and diagnosis (FDD) is an active field of research and has been studied in different application domains. Isermann (Isermann, 1997; Isermann, 2006) provided a general review for FDD. Katipamula and Brambley (Katipamula and Brambley, 2005a; Katipamula and Brambley, 2005b) conducted an extensive review in two parts on fault detection and diagnosis for building systems. Xue et al. (Xue et al., 2017) applied clustering analysis and association rule mining to detect faults in substations. Sandin et al. (Sandin et al., 2013) used probabilistic methods and heuristics for automated detection and ranking of faults in large-scale district energy systems. Calikus et al. (Calikus et al., 2019) proposed an approach for automatically 1) discovering heat load

patterns in DH systems and 2) identifying buildings with abnormal heat profiles and unsuitable control strategies.

In contrast to the above mentioned methods, this study proposes a multi-view data analysis approach that can be applied for monitoring, evaluating and visualizing the operational behaviour of DH substations. The geographical location data is used as a backbone of the analysis and the operational performance of the substations is further assessed in conjunction with their neighbours.

3 PROBLEM FORMALIZATION

We have a network with N nodes, e.g., a DH network linking a set of substations located in some geographical region. Assume that each network node, substation, i ($i = 1, 2, \dots, N$) is monitored under n different conditions (i.e., the measurements of n different features are collected) for a given time period, e.g., m days. Each monitored condition j ($j = 1, 2, \dots, n$) contains the measured levels of the corresponding feature for a period of m days in t different time points. This leads to a set of n time series data matrices D_j ($j = 1, 2, \dots, n$), one per feature, for each network node.

This multi-view data context can additionally be complicated in the case of a real-world scenario such as one related to a DH network. For example, the operational behaviour of the substations varies during heating and non-heating seasons which requires separate analysis. Therefore, for each substation two datasets are usually collected and available for further analysis and comparison. Notice that in this study, we are only interested in the operational behaviour of the DH substations during heating season due to the importance of space heating.

The main challenge in the above multi-view context is how to use all available measurements about the substations' operational behaviour and performance for better understanding and improved maintenance of the DH network. Exploiting the whole potential of these real-world datasets is not trivial and it requires suitable data analysis techniques to prevent information loss.

4 METHODS

4.1 Clustering Analysis

In this study, we are interested in identifying homogeneous groups of substations by considering their loca-

tions and additionally analysing them with respect to different views (features). Due to unavailability of the labeled data, clustering analysis is applied to explore hidden structures within the data. We apply two clustering algorithms as follows:

1. Minimum Spanning Tree Clustering: We use VanderPlas' (VanderPlas, 2016) Python implantation of the minimum spanning tree (MST) clustering algorithm for grouping substations based on their geographical location. The algorithm is based on constructing an approximate Euclidean minimum spanning tree (EMST), which considers only k nearest neighbours of each point for building the minimum spanning tree rather than the entire set of edges in a complete graph.

2. Affinity Propagation: We use the affinity propagation (AP) algorithm (Frey and Dueck, 2007) for clustering the time series based on their similarities. AP works based on the concept of *message passing* between data points to first identify a suitable set of exemplars and then to choose which data points should pick which exemplars. One of the advantages of AP, unlike other clustering algorithms, such as k -means (MacQueen et al., 1967) which requires the number of clusters as an input, is that it estimates the optimal number of clusters from the data. In addition, the chosen exemplars, the representative of the clusters, are real data points which makes AP a suitable clustering algorithm for this study.

4.2 Similarity Measures

We use different similarity measures, 1) to check the similarity between daily time series profiles of each feature, 2) to perform pairwise comparison between exemplars of clustering solutions of different substations, and 3) to compute a similarity between two clustering solutions by considering all pairs of members. These similarity measures are as follows:

1. Dynamic Time Warping: Given two time series $Y = (y_1, y_2, \dots, y_n)$ and $Y' = (y'_1, y'_2, \dots, y'_m)$, the similarity between Y and Y' can be measured using the dynamic time warping (DTW) algorithm. DTW is proposed by Sakoe and Chiba (Sakoe and Chiba, 1978) for spoken word detection with the focus of eliminating timing differences between two speech patterns. In other words, DTW identifies an optimal matching between the given sequences by warping the time axis. In order to align the time series Y and Y' of length n and m respectively, a cost matrix, $Q_{n \times m}$ is computed. Each element, q_{ij} , of $Q_{n \times m}$ corresponds to the distance (often Euclidean) between y_i and y'_j of the two series. Using the cost matrix, the DTW tries to find the best alignment path between these two time

series that is leading to minimum overall cost. The best warping path should satisfy a different number of conditions such as monotonicity, continuity, boundary, warping window, and slope constraint.

2. Clustering Solution Similarities: Given two clustering solutions $C = \{C_1, C_2, \dots, C_n\}$ and $C' = \{C'_1, C'_2, \dots, C'_m\}$ of datasets X and X' , respectively, the similarity, C_{S_w} , between C and C' can be assessed as follows (Abghari et al., 2019):

$$C_{S_w}(C, C') = \frac{\sum_{i=1}^n (\min_{j=1}^m w_i \cdot d(c_i, c'_j))}{2} + \frac{\sum_{j=1}^m (\min_{i=1}^n w'_j \cdot d(c_i, c'_j))}{2}, \quad (1)$$

where c_i and c'_j are exemplars of the clustering solution C_i and C'_j , respectively. The weights w_i and w'_j indicate the relative importance of clusters C_i and C'_j compared to other clusters in the clustering solution C and C' , respectively. For example, a weight w_i of a cluster C_i can be calculated as the ratio of its cardinality with respect to the size of X , i.e., $w_i = |C_i|/|X|$. The C_{S_w} has values in a range of $[0, 1]$. Scores equal to zero imply identical performance while scores close to one show significant dissimilarities.

3. Adjusted Rand Index: The quality of the results of a clustering analysis can be validated by means of *internal* and *external* criteria. Internal criteria evaluate the quality of the clustering solution produced by a clustering algorithm that fits the data in terms of, e.g., compactness and separation by using the inherent information of the data. External criteria on the other hand, can be used for measuring the level of agreements between the results of a clustering algorithm in comparison with ground truth, the results of another clustering algorithm on the same data, or same clustering algorithm but by considering different views.

In this study, we apply a symmetric external validation index for assessing the similarity (consensus) between two clustering results generated on the studied DH substations with respect to two different views. The adjusted Rand index (ARI) (Hubert and Arabie, 1985) is a correction of the Rand index (RI) (Rand, 1971) that measures the similarity between two clustering solutions by considering the level of agreements between the two groups. ARI is computed as follows:

$$ARI = \frac{RI - ExpectedRI}{Max(RI) - ExpectedRI} \quad (2)$$

ARI scores are bound between -1 and +1. A score less than or equal to 0 represents random labelling and 1 stands for perfect match.

5 PROPOSED APPROACH

Geographical locations of N substations are initially used for building an approximate graph representation of the DH network. We refer to the geographical location of the substations as the Location view (v_0). This is performed by applying the MST clustering algorithm described in Section 4. The aim is to connect substations based on their distance by building a minimum spanning tree and removing edges of the tree with regard to a cut-off threshold. Therefore, each cluster is represented by a tree that can be interpreted as a representation of the DH network structure. In order to provide additional support for the domain experts, the graph representation can in turn be used as a backbone for additional information about the DH network, e.g., average yearly values and different forms of ranking.

On the foundation of the created grouping of the substations we can perform further analysis by focusing on a specific feature or subset of features and evaluate the substations' operational behaviours in each single location-based cluster. We study and evaluate the following two scenarios:

1. Step-wise multi-view clustering (SW-MVC), we can apply clustering analysis on substations that have been grouped together at the previous step with respect to a set of features, i.e., the substations can be grouped by considering one feature at a time. This scenario can be used when the domain experts are interested in grouping similar substations based on their performance with respect to one feature and then finding similar substations in each group by using another feature and so on. Figure 1 shows how the results of this analysis can be visualized based on the location of the substations and two features.




Figure 1: SW-MVC analysis, each view represents the clustering analysis based on one feature. Every analysing step is based on the results obtained on the previously considered view. Triangles represent substations.

As an example, consider two substations s_i and s_j in the cluster C_{00} from v_0 , where the similarity of the two substations can be analysed in terms of their op-

erational behaviour, first based on Feature 1 (v_1) and then Feature 2 (v_2). Here two scenarios can occur, either s_i and s_j are grouped together with respect to v_1 , since they performed similarly, or they are assigned into different groups. In case of the first scenario, after applying the second step of the analysis (i.e., using v_2) if s_i and s_j are in the same group this shows that the operational behaviour of the two substations are similar with respect to v_1 and v_2 . Otherwise, the two substations are only similar with regards to v_1 and dissimilar with regards to v_2 . In case of the second scenario, the substations are dissimilar with respect to both views. Nevertheless, in all cases the domain expert might be interested to further analyse groups of substations with a smaller size.

2. Parallel-wise multi-view clustering (PW-MVC), in this scenario a group of substations can be studied by considering different features in parallel. For example, the substations can be clustered separately with respect to two different features (or subsets of features). The produced clustering solution can further be compared and analysed to find out whether similar substations, that have been grouped together based on one feature, are still in the same group with respect to the other feature. In addition, one can use a *bipartite graph*, to present and visualize the relationships between a clustering solution based on one view and a clustering solution produced on the other view. This will provide domain experts more information by supplying them with deeper insights about substations' operational behaviours in different groups with regards to two different views. For further analysis, one can label clusters of each clustering solution with performance indicators¹ and rank them from the highest to the lowest performance.

The results of this pairwise comparison can be used in conjunction with the SW-MVC analysis to provide a better understanding of operational behaviour for each individual substation and the group as a whole. Our initial assumption is that using the SW-MVC analysis, one can construct a hierarchical graph-model of a heating network for the area of study. Those substations that are located in the same cluster are assumed to share similar characteristics. While the PW-MVC analysis focus is on identifying a similar group of substations that are in the intersection of the two views.

¹The operational performance of a DH substation can be evaluated with respect to different indicators, which are usually computed based on the quantitative relation between the substation's inputs and outputs.

6 EXPERIMENTS AND EVALUATION

6.1 Dataset

The data used in this study is provided by an energy company. The data consists of hourly average measurements from 70 substations located in Southern Sweden during 2015 to 2018. The dataset contains eight features both from primary and secondary sides of the DH network. The primary side data is always available. The secondary side data on the other hand, requires specific hardware to be extracted. Therefore, in this study we mainly focus on primary side data to analyse the operational behaviour of the DH substations.

Apart from these features there are two performance indicators that are computed using both sides of the DH network. The first indicator is called the *least temperature difference* (Frederiksen and Werner, 2013) which represents the difference between primary and secondary return temperatures. The least temperature difference of a substation can be greater than or equal to zero, though it can go below zero due to usage of DHW. A lower value of this indicator implies better performance. The second indicator is referred to as *substation effectiveness*. It is the ratio of the difference between primary supply and return temperatures to the difference between primary supply temperature and the secondary return temperature. The efficiency of a well-performing substation should be close to one in a normal setting. However, due to the affect of DHW generation on the primary return temperature, it can represent values above one. Table 1 shows the dataset features and the performance indicators.

Table 1: Features included in the dataset.

No.	Feature	Notation	Unit
1	T_o	Outdoor temperature	°C
2	$T_{s,1st}$	Primary supply temperature	°C
3	$T_{r,1st}$	Primary return temperature	°C
4	ΔT_{1st}	Primary delta temperature	°C
5	G_{1st}	Primary mass flow rate	l/h
6	Q_{1st}	Primary heat	kW
7	$T_{s,2nd}$	Secondary supply temperature	°C
8	$T_{r,2nd}$	Secondary return temperature	°C

Figure 2 shows the groups and graph network representation produced by applying MST clustering on the above mentioned 70 substations. The substations are partitioned into nine clusters by applying the MST clustering algorithm while the cut-off parameter is set to 500 meters. That is substations with distance less




Figure 2: 70 substations located in Southern Sweden are grouped into nine clusters using the MST clustering algorithm. The geographical location of the substations is referred to as the Location view (v_0). Substations with distance less than 500 meters from their closest neighbours are grouped together. The color of the substations represents the average $T_{s,1^{st}}$ in January 2018, which for most substations is around 87 °C.

than 500 meters from their closest neighbour(s) are grouped together. Five clusters represent as a tree, i.e., edges of the tree represent the distance between the substations (the tree nodes) and the remaining four clusters are singletons. The substations' colors represent their received average $T_{s,1^{st}}$ (°C) in January 2018.

In order to make the data ready for the experiment, first the duplicates are removed. Then we focused on extreme values which can appear as a result of faults in measurement tools. We apply a Hampel filter (Hampel, 1971) which is a median absolute deviation (MAD) based estimation to detect and smooth out such extreme values. The filter is used with the default parameters, i.e., the size of the window is set to be seven and the threshold for extreme value detection is set to be three.

In the studied context, we have hourly measurements data. This gives one time series every 24-hours and in total 365 time series per year. Time series with less than 24 measurement values are excluded. Since we are expecting different behaviours from a DH substation during heating and non-heating seasons, the time series are divided into two groups with respect to the outdoor temperature (T_o). That is, if the outdoor temperature is above a certain threshold, $T_{o,threshold}$, the DH substation behaviour can be categorized into the non-heating season otherwise to the

heating season. This threshold in Sweden can be set to be $T_{o,threshold} = 10$ °C. In order to assess each DH substation's operational behaviours during heating season and in comparison with other substations, the extracted time series are scaled with z-score normalization. That is, each time series is scaled to have a mean of zero and a standard deviation of one. Notice that in the considered context the general shape of the time series, rather than their amplitude, is important. Now for every category, the time series related to one specific feature, i , can be compared in terms of similarity with respect to a distance measure $d(y_i, y_j)$, where d in this study is DTW . This leads to a similarity matrix, SM_i . In the next step, SM_i is fed to a clustering algorithm. Here we aim to group time series based on their similarities into a number of clusters. Considering each feature as one view, we can analyse the operational behaviour of a set of DH substations by using the explained evaluation scenarios in Section 5.

6.2 Implementation and Availability

The proposed approach is implemented in Python version 3.6. The affinity propagation and the adjusted Rand index are adopted from the scikit-learn module (Pedregosa et al., 2011) and the MST clustering algorithm is fetched from (VanderPlas, 2016). The

alignments between time series are identified using dtwalign’s package². The implemented code and the experimental results are available at GitHub³.

7 RESULTS AND DISCUSSION

The initial view in our analyses is always the outcome of the MST clustering, i.e., 70 substations in the studied area are grouped into nine clusters based on their distances. We set the cut-off parameter to be 500 meters which means any edges greater than 500 meters are removed from the MST. The first three clusters (0, 1, and 2) include 15, 32, and 14 substations, respectively (in total 61 of 70 substations). The remaining substations are grouped into 6 clusters as follows: cluster 3 contains 2 substations, clusters 4, 5, 7, and 8 are singletons and cluster 6 has 3 substations.

In the remainder of this study we only consider and discuss the results produced on clusters 0, 1, and 2, since the majority of the substations are distributed in these clusters. Each analysis can be performed based on different combinations of the features in Table 1. However, due to the page limit, we only report the results of the analyses with respect to $T_{r,1st}$ and ΔT_{1st} (the difference between $T_{s,1st}$ and $T_{r,1st}$).

7.1 SW-MVC Analysis

Table 2 shows the results of SW-MVC analysis for 61 substations throughout the heating seasons from 2015 to 2018. For each MST cluster (v_0), initially substations are grouped based on $T_{r,1st}$ (v_1) and then for each created subgroup the clustering analysis is performed using ΔT_{1st} (v_2). The information in Table 2 can be used in three different ways: column-wise, row-wise, or both. In the column-wise case, one can see how the substations in each MST cluster are grouped based on the other two views (i.e., v_1 and v_2) in different years. The row-wise analysis shows how the substations in each MST cluster are grouped step-wise based on first v_1 and second v_2 . For example, the domain experts might be interested in performing further analysis when the grouped substations in v_1 are split into more subgroups based on v_2 . Numbers in bold in Table 2 represent the number of substations that are grouped into different clusters based on v_2 as opposed to v_1 . By considering both cases one can track the transition of the operational behaviour of substations throughout the years.

²<https://github.com/statefb/dtwalign>

³<https://github.com/shahrooz-abghari/MVC-DH-Monitoring>

Table 2: SW-MVC analysis based on $T_{r,1st}$ and ΔT_{1st} from 2015 to 2018.

Year	$v_0 : MST$	$v_1 : T_{r,1st}$		$v_2 : \Delta T_{1st}$		
	Label	#substations	Label	0	1 2	Total
2015	0	5	0	5		5
		10	1	1	9	10
		32	0	11	12	9
2015	1	5	0	3	2	5
		9	1	6	3	9
		3	0	3		3
2016	0	5	1	4	1	5
		7	2	7		7
		15	0	9	6	15
2016	1	13	1	7	6	13
		4	2	4		4
		9	0	9		9
2017	0	8	0	8		8
		1	1	1		1
		5	2	5		5
2017	1	1	3	1		1
		11	0	8	3	11
		4	1	1	3	4
2018	0	16	2	8	8	16
		1	3	1		1
		2	0	2		2
2018	1	9	1	9		9
		3	2	3		3
		1	0	1		1
2018	2	14	1	10	4	14
		12	0	12		12
		5	1	5		5
2018	1	8	2	5	3	8
		7	3	6	1	7
		4	0	1	3	4
2018	2	4	1	4		4
		1	2	1		1
		5	3	5		5

Note. Number of substations that are grouped into different clusters based on v_2 as opposed to v_1 are shown in **bold**.

Figure 3 depicts the SW-MVC analysis by considering $T_{r,1st}$ as the first view (squares) and ΔT_{1st} as the second view (circles) in the period from 2015 to 2018.

Figure 4 represents the SW-MVC analysis specifically for the MST cluster with label 0 during a period covering 2017 and 2018. Notice, the color of squares shows $T_{r,1st}$ while the colored circles represent ΔT_{1st} . These two features can be used as an assessment indicator for the operational behaviour of the substations. Technically, it is desired in a well performed substation that the $T_{r,1st}$ has a lower value in comparison to the $T_{s,1st}$. In other words, a greater delta means that the substation is making more efficient use of the supplied heat for space heating.

Table 3 provides the statistics, the average values




Figure 3: The results of SW-MVC analysis for the whole studied area contains 70 substations. Squares represent clusters of substations based on the first view, $T_{r,1st}$, and circles represent groups of substations with respect to the second view, ΔT_{1st} . Note that the substations with similar colors in different MST clusters are not related.

of the actual measurements and their standard deviations, regarding the DH substations that are discussed in Figure 4. As one can see in 2017, substations are grouped into 4 clusters, where clusters 0 (green squares) and 2 (orange squares) contains the majority of substations, 8 and 5, respectively. The two other clusters include only one substitution each (red squares). The average $T_{r,1st}$ for cluster 0 is approximately 43 °C and for cluster 2 is around 46 °C. Clusters 1 and 3 both show the average $T_{r,1st}$ of 48 °C. All the grouped substations in the previous step stayed together based on the ΔT_{1st} , i.e., no new cluster is created. The cluster with 8 substations (grey circles inside green squares) represents the ΔT_{1st} of 34.79 °C, while the cluster with 5 substations (yellow circles inside orange squares) shows the ΔT_{1st} of 33.26 °C. The other two clusters (yellow circles inside red squares) show the same value, 34.25 °C for the ΔT_{1st} .

In 2018, the same number of substations, 15, are grouped into only two clusters with an average $T_{r,1st}$ of approximately 40 °C for cluster 0 (purple square) and 44 °C for cluster 1 (orange squares). A majority of the substations, 13 out of 14, are grouped in cluster 1. This cluster is further divided into two clusters, one with 10 DH substations (grey circles inside orange squares) and the average ΔT_{1st} of approximately 34 °C and the other with 4 substations (orange circles inside orange squares) and the average ΔT_{1st} of




Figure 4: The results of SW-MVC analysis for the MST cluster with label 0 and 15 substations in 2017 (top) and 2018 (bottom). Colored squares represent groups of substations based on $v_1 : T_{r,1st}$ and colored circles represent groups of substations based on $v_2 : \Delta T_{1st}$.

Table 3: SW-MVC analysis for the MST cluster with label 0, 2017 to 2018.

Year	$v_0 : MST$		$v_1 : T_{r,1st}$				$v_2 : \Delta T_{1st}$			
	Label	#substations	Avg(°C)	SD(°C)	Label	#substations	Avg(°C)	SD(°C)		
2017	0	0	8	43.31	5.39	0	8	34.78	4.13	
		1	1	47.88	-	0	1	34.25	-	
		2	5	46.23	3.35	0	5	33.26	3.01	
		3	1	47.61	-	0	1	34.25	-	
2018	0	0	1	39.91	-	0	1	31.01	-	
		1	14	44.31	4.66	0	10	33.71	4.11	
		1	4	36.63	2.10					

Note. Avg: average, SD: standard deviation

approximately 37 °C. Cluster 0 represents one substation (yellow circle inside purple square) with the average ΔT_{1st} of 31.01 °C. In both years there are substations that show slightly different operational behaviour in comparison to their neighbouring substations, e.g., the red substations in 2017 and the purple substation in 2018. The domain experts can investigate the reasons why these substations performed differently in comparison to the majority of substations. In addition, it is important to mention that the order in which views are used for the SW-MVC analysis affects the results, which can be decided based on the domain expert’s preferences.

7.2 PW-MVC Analysis

The aim of this analysis is to group the substations based on two different views (i.e., v_1 and v_2) and compare the results of the clustering solution to find out which substations are similar based on both views. Such analysis can provide useful information for the domain experts while it applies for a period of time, e.g., different years, where the transition of the operational behaviour of substations can be monitored. Table 4 shows the distribution of the studied substations based on PW-MVC analysis throughout the heating season in the period from 2015 to 2018.

Figure 5 depicts the computed ARI scores for the clustering solution based on $T_{r,1st}$ and ΔT_{1st} of each MST cluster in the period from 2015 to 2018. As one can see, the ARI scores of the first three clusters are absolutely dissimilar in 2015, 2016, and 2018. However, cluster 2 with 14 substations shows the ARI score of 0.71 in 2017, which means the majority of DH substations in this cluster performed similarly. Other clusters, 3 to 8 represent the adjusted Rand index of 1 for all the years.

Figure 6 shows the PW-MVC analysis for MST cluster with label 1 with respect to $T_{r,1st}$ and ΔT_{1st} in the period from 2015 to 2018. The substations with similar cluster labels with regard to both features are shown in red. The insight provided by Figure 6 can

Table 4: PW-MVC analysis is performed based on $T_{r,1st}$ and ΔT_{1st} separately from 2015 to 2018.

Year	$v_0 : MST$		$v_1 : T_{r,1st}$				$v_2 : \Delta T_{1st}$		
	Label	#substation	0	1	2	3	0	1	2
2015	0	15	5	10			5	10	
	1	32	32				11	12	9
	2	14	5	9			6	5	3
Total		70	51	19			31	27	12
2016	0	15	3	5	7		6	9	
	1	32	15	13	4		32		
	2	14	9	5			10	4	
Total		70	36	23	11		57	13	
2017	0	15	8	1	5	1	15		
	1	32	11	4	16	1	10	22	
	2	14	2	9	3		10	4	
Total		70	30	14	24	2	44	26	
2018	0	15	1	14			9	6	
	1	32	12	5	8	7	26	6	
	2	14	4	4	1	5	4	10	
Total		70	26	23	9	12	48	22	




Figure 5: PW-MVC analysis, the computed ARI scores for $T_{r,1st}$ and ΔT_{1st} throughout 2015 to 2018.

be used for analysing the difference between operational behaviour of the red substations against the greys within one specific year. In addition, the transition of the substations from one color group to another can be tracked and further analysed.




Figure 6: The results of PW-MVC analysis for the MST cluster with label 1 and 32 substations. Substations in red are those that are grouped with the same label according to the both views, namely $T_{r,1^{\sigma}}$ and $\Delta T_{1^{\sigma}}$ from 2015 to 2018.

8 CONCLUSIONS

We have proposed a multi-view clustering approach for analysing datasets that consist of different data representations. The proposed approach has been applied for monitoring and analysing operational behaviour of district heating substations. We have initially used the substations' geographical information to build an approximate graph representation of the DH network. This graph structure has been used as a backbone for further analysis of the network performance.

In the above context, we have proposed and discussed two different types of analysis: 1) step-wise multi-view clustering that sequentially considers and analyses the operational behaviour of the DH substations with respect to different views and organizes the substations into a hierarchical structure. That is, at each step a new clustering solution is built on top of the one generated in the previous step with respect to the considered view. 2) parallel-wise multi-view clustering that analyses substations with regards to two different views in side by side. This enables the identification of the relationships between neighbouring

substations by organizing them in a bipartite graph and analysing their distribution with respect to the two considered views. The proposed data analysis approach facilitates the visual analysis and inspections of multi-view real-world datasets such as ones related to the DH networks. For example, the proposed approach provides the opportunity to consider the DH substations in close relation with their neighbours. That is, those substations that demonstrate a deviating behavior from their neighbouring substations can easily be identified for further investigation.

For future work, we are interested in expanding our approach by adding a third scenario where the clustering solution is the outcome of integration of different views. We believe that the proposed approach provides a verity of analysis techniques to supply the domain experts with a complete picture about the DH network operations. In addition, the proposed approach can facilitate the identification of substations with deviating behaviours and suggest initiation of further inspections by domain experts.

ACKNOWLEDGEMENTS

This work is part of the research project “*Scalable resource-efficient systems for big data analytics*” funded by the Knowledge Foundation (grant: 20140032) in Sweden.

We would also like to thank Christian Johansson, CEO of NODA Intelligent Systems, for his support and valuable feedback.

REFERENCES

- Abghari, S., Boeva, V., Brage, J., Johansson, C., Grahn, H., and Lavesson, N. (2019). Higher order mining for monitoring district heating substations. In *2019 IEEE Int'l Conf. on Data Science and Advanced Analytics (DSAA)*, pages 382–391. IEEE.
- Ando, R. K. and Zhang, T. (2007). Two-view feature generation model for semi-supervised learning. In *Proc. of the 24th Int'l Conf. on Machine learning*, pages 25–32. ACM.
- Bickel, S. and Scheffer, T. (2004). Multi-view clustering. In *ICDM*, volume 4, pages 19–26.
- Blum, A. and Mitchell, T. (1998). Combining labeled and unlabeled data with co-training. In *Proc. of the eleventh annual Conf. on Computational learning theory*, pages 92–100.
- Cai, X., Nie, F., and Huang, H. (2013). Multi-view k-means clustering on big data. In *Twenty-Third Int'l Joint Conf. on artificial intelligence*.
- Calikus, E., Nowaczyk, S., Sant'Anna, A., Gadd, H., and Werner, S. (2019). A data-driven approach for discovery of heat load patterns in district heating. *arXiv preprint arXiv:1901.04863*.
- Deepak, P. and Anna, J.-L. (2019). *Multi-View Clustering*, pages 27–53. Springer Int'l Publishing, Cham.
- Frederiksen, S. and Werner, S. (2013). *District Heating and Cooling*. Studentlitteratur AB.
- Frey, B. J. and Dueck, D. (2007). Clustering by passing messages between data points. *Science*, 315(5814):972–976.
- Hampel, F. R. (1971). A general qualitative definition of robustness. *The Annals of Mathematical Statistics*, pages 1887–1896.
- Hubert, L. and Arabie, P. (1985). Comparing partitions. *J. of classification*, 2(1):193–218.
- Isermann, R. (1997). Supervision, fault-detection and fault-diagnosis methods—an introduction. *Control engineering practice*, 5(5):639–652.
- Isermann, R. (2006). *Fault-diagnosis systems: an introduction from fault detection to fault tolerance*. Springer Science & Business Media.
- Jiang, B., Qiu, F., and Wang, L. (2016). Multi-view clustering via simultaneous weighting on views and features. *Applied Soft Computing*, 47:304–315.
- Katipamula, S. and Brambley, M. R. (2005a). Methods for fault detection, diagnostics, and prognostics for building systems-A review, part I. *Hvac&R Research*, 11(1):3–25.
- Katipamula, S. and Brambley, M. R. (2005b). Methods for fault detection, diagnostics, and prognostics for building systems-A review, part II. *Hvac&R Research*, 11(2):169–187.
- Kumar, A. and Daumé, H. (2011). A co-training approach for multi-view spectral clustering. In *Proc. of the 28th Int'l Conf. on machine learning (ICML-11)*, pages 393–400.
- Liu, J., Wang, C., Gao, J., and Han, J. (2013). Multi-view clustering via joint nonnegative matrix factorization. In *Proc. of the 2013 SIAM Int'l Conf. on Data Mining*, pages 252–260. SIAM.
- MacQueen, J. et al. (1967). Some methods for classification and analysis of multivariate observations. In *Proc. of the Fifth Berkeley Symp. on Mathematical Statistics and Probability*, volume 1, pages 281–297. Oakland, CA, USA.
- Meng, X., Liu, X., Tong, Y., Glänzel, W., and Tan, S. (2015). Multi-view clustering with exemplars for scientific mapping. *Scientometrics*, 105(3):1527–1552.
- Pedregosa, F., Varoquaux, G., Gramfort, A., Michel, V., Thirion, B., Grisel, O., Blondel, M., Prettenhofer, P., Weiss, R., Dubourg, V., Vanderplas, J., Passos, A., Cournapeau, D., Brucher, M., Perrot, M., and Duchesnay, E. (2011). Scikit-learn: Machine learning in Python. *J. of Machine Learning Research*, 12:2825–2830.
- Rand, W. M. (1971). Objective criteria for the evaluation of clustering methods. *J. of the American Statistical association*, 66(336):846–850.
- Sakoe, H. and Chiba, S. (1978). Dynamic programming algorithm optimization for spoken word recognition. *IEEE Transactions on Acoustics, Speech, and Signal Processing*, 26(1):43–49.
- Sandin, F., Gustafsson, J., and Delsing, J. (2013). *Fault detection with hourly district energy data: Probabilistic methods and heuristics for automated detection and ranking of anomalies*. Svensk Fjärrvärme.
- VanderPlas, J. (2016). mst.clustering: Clustering via euclidean minimum spanning trees. *J. Open Source Software*, 1(1):12.
- Wang, C.-D., Lai, J.-H., and Philip, S. Y. (2015). Multi-view clustering based on belief propagation. *IEEE Transactions on Knowledge and Data Engineering*, 28(4):1007–1021.
- Wang, X., Qian, B., Ye, J., and Davidson, I. (2013). Multi-objective multi-view spectral clustering via pareto optimization. In *Proc. of the 2013 SIAM Int'l Conf. on Data Mining*, pages 234–242. SIAM.
- Xu, C., Tao, D., and Xu, C. (2013). A survey on multi-view learning. *arXiv preprint arXiv:1304.5634*.
- Xue, P., Zhou, Z., Fang, X., Chen, X., Liu, L., Liu, Y., and Liu, J. (2017). Fault detection and operation optimization in district heating substations based on data mining techniques. *Applied Energy*, 205:926–940.
- Zong, L., Zhang, X., Zhao, L., Yu, H., and Zhao, Q. (2017). Multi-view clustering via multi-manifold regularized non-negative matrix factorization. *Neural Networks*, 88:74–89.