

SIMULATION AND FORMAL VERIFICATION OF REAL TIME SYSTEMS: A CASE STUDY

Eurico Seabra, José Machado, Jaime Ferreira da Silva

Mechanical Engineering Department, Engineering School, University of Minho, 4800-058 Guimarães, Portugal

Filomena O. Soares

Industrial Electronics Department, Engineering School, University of Minho, 4800-058 Guimarães, Portugal

Celina P. Leão

Production System Department, Engineering School, University of Minho, 4800-057 Braga, Portugal

Keywords: Real Time Systems, Plant Models, Object-Oriented Language, Formal Verification.

Abstract: This paper presents and discusses a case study that applies techniques of simulation together with techniques of formal verification. A new approach in the plant modelling for formal verification of timed systems is presented. The modelling of the plant was performed by using the object-oriented language Modelica with the library for hierarchical state machines StateGraph and the simulation results were used as input for the formal verification tasks, using the model checker UPPAAL. It is presented, in a more detailed way, the part of this work that is related to the plant simulation.

1 INTRODUCTION

Modern engineered systems have reached a high degree of complexity that requires systematic design methodologies and model-based approaches to ensure the correct and competitive performance. In particular, the use of digital controllers has been proven that small errors in their design may lead to catastrophic failures.

Recent years have witnessed a significant growth of interest in the modelling and simulation of physical systems. A key factor in this growth was the development of efficient equation-based simulation languages. Such languages have been designed to allow automatic generation of efficient simulation code from declarative specifications. The Modelica language (Fritzson *et al.* 1998, Elmqvist *et al.* 1999, Fritzson *et al.* 2002) and its associated support technologies have achieved considerable success through the development of specific libraries. However, a significant part of the software development effort is spent on detecting deviations from specifications and subsequently localizing the

sources of such errors. The high-level of abstraction of equation-based models presents new challenges to modelling and simulation tools due to the large gap between the declarative specification and the executable machine code. This abstraction gap leads to difficulties in finding and correcting model inconsistencies and errors, which are not uncommon in the process of developing complex physical system models.

Among the several techniques of industrial controllers analysis available, Simulation (Baresi *et al.* 2000, Baresi *et al.* 2002) and Formal Verification (Moon, 1994, Roussel and Denis, 2002), can be distinguished due to their utility. In the research works on industrial controller's analysis, these two techniques are rarely used simultaneously. If the Simulation is faster to execute, it presents the limitation of considering only some system behaviour evolution scenarios. Formal Verification presents the advantage of testing all the possible system behaviour evolution scenarios but, sometimes, it takes a large amount of time for the attainment of formal verification results. In this

paper it is shown, as it is possible, and desirable, to conciliate these two techniques in the analysis of industrial controllers. With the simultaneous use of these two techniques, the developed industrial controllers are more robust and not subject to errors.

Using this approach, the command of those systems can be simulated and tested when the physical part of the machine still does not exist. This way of simulation allows to reduce the production times of the automation systems because the manufacture do not need the physical part of the machine for later perform tests and simulation of the command of the system. This paper is focused in the simulation of timed systems.

To accomplish our goals, in this work, the paper is organized as follows. In Section 1, it is presented the challenge proposed to achieve in this work. Section 2 presents a general presentation of the case study involving a system with two tanks, a heating device, a mixer device, level control sensors and valves to control the liquids flow. Further, it is presented the methodology to obtain the controller program deduced from an IEC 60848 SFC specification of the system desired behaviour. Section 3 is exclusively devoted to the plant modelling, being presented the adopted approach. Section 4 presents and discusses the obtained results on simulation performed with the Modelica Language. Finally, in Section 5, the main conclusions and future work are presented.

2 SYSTEM DESCRIPTION

The case study is an adapted version of the benchmark example presented by (Kowalewski *et al.* 2001) and (Huuck *et al.* 2001) that corresponds to an evaporator system.

The system (Fig. 1) consists of two tanks, where tank1 is heated and mixed, one condenser, two level analogue sensors (one for each tank) and four on-off valves.

In the normal operation, the system works as follows. Tank1 is filled with two solutions by opening valves V1 and V2. When the level becomes high, the valves are closed and liquids are mixed by a mixer device for dilution. After two time units, the heating device is switch on to increase the temperature of the solution. After 20 time units, the required concentration has been reached and the heater is switched off. Meanwhile, during the heating phase, part of the liquid has been evaporated and cooled by the condenser. The remaining part is drained in tank2 by opening the valve V3. When the

first tank is empty, the mixer is stopped and the solution in tank2 stays for post-processing step, to stay liquid, for 32 time units. At that point, the valve V4 is opened to empty tank2.




Figure 1: Scheme of the evaporator system.

Throughout normal operation mode, the system may malfunction. During evaporation, the condenser may fail: the steam can not be cooled and the pressure inside the condenser rises. Therefore, the heater must be switched off to avoid the condenser explosion. By doing so, the temperature of tank1 decreases and the solution may become solid and can not be drained in tank2. Hence, valve V3 must be opened early enough for preventing tank2 overflow, but after opening first valve V4.

In the case of a condenser malfunction, it is also necessary to ensure that some response times of the control program, taking into account the timing characteristics of the physical devices:

- whenever a condenser malfunction starts, the condenser can explode if steam is produced during 22 time units;
- if the heating device is switched off, the steam production stops after 12 time units;
- if no steam is produced in tank 1, the solution may solidify after 19 time units;
- emptying tank 2 takes between 0 and 26 time units;
- filling tank 1 takes 6 time units, at most.

2.1 Controller

In order to guarantee the desired behaviour of the evaporator system described above, the controller was developed according to IEC 60848 SFC specification, which is presented in Figure 2.

The PLC program which controls the process in closed-loop has input and output variables as described in Table1.

Table 1: Input/Output variables of the controller.

Input	Output
start – process start	V1 – open valve1
level1 – % fill tank1	V2 – open valve2
level2 – % fill tank2	V3 – open valve3
malf – condenser	V4 – open valve4
malfunction	H – switch Heater on
	MR – switch Mixer on
	Alarm – start alarm

The tank level is given in % of the fill tank. In this research work, the Boolean variables T1F (tank1 full) and T2F (tank2 full) were considered true when the level1 and level2 was greater than 0.98, respectively. On the other hand, the Boolean expression T1E (tank1 empty) and T2E (tank2 empty) were assumed true when the level1 and level2 was less than 0.01, respectively.




Figure 2: SFC of the system controller.

3 PLANT MODEL

The plant modelling was carried out in two steps. First, the plant was modelled using the Dymola program and the object-oriented language Modelica (Elmqvist and Mattson, 1997) with the library for hierarchical state machines StateGraph (Otter, 2005). Subsequently, the obtained models were used

as a base to develop the UPPAAL (David *et al.* 2003) models that are used on formal verification tasks.

It should be highlighted that the most important data obtained by the Modelica simulation considered on the formal verification tasks is the set of simulation functioning delays. These delays are used to define the time units used on the UPPAAL modules of the plant model (Machado *et al.* 2007).

As the main aim of this paper deals with the plant simulation by using Modelica Language, it is only presented the modelling of tank1 by UPPAAL.

3.1 Tank1

The tank1 model is first simulated by using the Dymola software with the Modelica program code presented in the Figure 3. The obtained times from the simulation were used on formal verification with UPPAAL.

```

model Tank1
  Modelica.Blocks.Interfaces.RealOutput levelSensor;
  Modelica.StateGraph.Examples.Utilities.inflow inflow1;
  Modelica.StateGraph.Examples.Utilities.outflow outflow1;
  Real level "Tank level in % of max height";
  parameter Real a=1 "ground area of tank in m^2";
  parameter Real a=0.2 "area of drain hole in m^2";
  parameter Real hmax=1 "max height of tank in m";
  constant Real g=Modelica.Constants.g_m;
  Modelica.StateGraph.Examples.Utilities.inflow inflow2;
equation
  der(level) = (inflow1.Fi + inflow2.Fi - outflow1.Fo)/(hmax*A);
  if outflow1.open then
    outflow1.Fo = sqrt(2*g*hmax*level)*a;
  else
    outflow1.Fo = 0;
  end if;
  levelSensor = level;
end Tank1;

connector Modelica.Blocks.Interfaces.RealOutput =
  output RealSignal "output Real as connector";

connector Modelica.Blocks.Interfaces.RealSignal
  "Real port (both input/output possible)"
  replaceable type SignalType = Real;
  extends SignalType;
end RealSignal;

connector Modelica.StateGraph.Examples.Utilities.inflow
  import Units = Modelica.SIunits;
  Units.VolumeFlowRate Fi "inflow";
end inflow;

connector Modelica.StateGraph.Examples.Utilities.outflow
  import Units = Modelica.SIunits;
  Units.VolumeFlowRate Fo "outflow";
  Boolean open "valve open";
end outflow;
    
```

Figure 3: Modelica program code for the model of tank1.

Figure 4 shows the corresponding model of the tank1 developed by UPPAAL for formal verification purposes.




Figure 4: UPPAAL model of the tank1.

3.2 Tank2

The Modelica program code for modelling the tank2, presented in Figure 5, is similar to the code obtained for the tank1 model. The main difference between these two codes is due to the tanks have different numbers of fill sources. The tank 1 has two fill sources while the tank 2 has one only.

```

model Tank2
  Modelica.Blocks.Interfaces.RealOutput levelSensor;
  Modelica.StateGraph.Examples.Utilities.inflow inflow1;
  Modelica.StateGraph.Examples.Utilities.outflow outflow1;
  Real level "Tank level in % of max height";
  parameter Real A=1 "ground area of tank in m^2";
  parameter Real a=0.2 "area of drain hole in m^2";
  parameter Real hmax=1 "max height of tank in m";
  constant Real g=Modelica.Constants.g_n;
equation
  der(level) = (inflow1.Fi - outflow1.Fo)/(hmax*A);
  if outflow1.open then
    outflow1.Fo = sqrt(2*g*hmax*level)*a;
  else
    outflow1.Fo = 0;
  end if;
  levelSensor = level;
end Tank2;

connector Modelica.Blocks.Interfaces.RealOutput =
  output RealSignal "output Real as connector";

connector Modelica.Blocks.Interfaces.RealSignal
  "Real port (both input/output possible)"
  replaceable type SignalType = Real;
  extends SignalType;
end RealSignal;

connector Modelica.StateGraph.Examples.Utilities.inflow
  import Units = Modelica.SIunits;
  Units.VolumeFlowRate Fi "inflow";
end inflow;

connector Modelica.StateGraph.Examples.Utilities.outflow
  import Units = Modelica.SIunits;
  Units.VolumeFlowRate Fo "outflow";
  Boolean open "valve open";
end outflow;

```

Figure 5: Modelica program code for the model of tank2.

4 SIMULATION RESULTS

In order to perform the simulation, it is necessary to define the parameters, start and stop time of the simulation, the interval output length or number of output intervals and the integration algorithm. In the present work, in all simulations performed, the Dass algorithm (Basu, 2006) with 500 output intervals was used.

In order to study the system behaviour different values for physical variables of the plant were used. Table 2 shows the variables considered in the simulation of the plant model.

Table 2: Variables of the plant.

Plant	Variable
source1, source 2	Q1, Q2 - flow rate [m ³ /s]
tank1, tank2	G1, G2 - ground area [m ²]
	Ht1, Ht2 -height [m]
	A1, A2 - drain hole area [m ²]

The first two simulation performed were devoted to verify if the SFC of the controller system (Fig.2) modelled with Modelica language with the library for hierarchical state machines StateGraph simulated correctly the evaporator system, respectively, in their normal and malfunction operation. The values for the plant variables considered in these simulations were Q1=1, Q2=0.5, G1=G2=1, Ht1=Ht2=1, A1=0.2 and A2=0.05.

Figures 6 and 7 show results of the simulation without the occurrence of the condenser malfunction during the production cycle, which corresponds to the normal operation, respectively, for the level tanks and for the controller outputs.

Observing Figures 6 and 7 it can be concluded that the system is properly simulated by the developed program, since during the time specified by the SFC the tanks remain filled and empty, as well as, the switch logical state of the controller outputs.

On the other hand, Figures 8 and 9 show results of the simulation with the occurrence of the condenser malfunction during the production cycle, which corresponds to the malfunction operation. The malfunction occurred in a random way 15s after the start of the plant functioning.

Analysing Figures 8 and 9 it can be also concluded that the malfunction operation is properly simulated by the proposed program. Because it can be verified, taking into account the Figure 8, that at the malfunction occurrence (time 15s) the solution present in the tank1 is immediately drained for the tank2 and later emptied. In the same way, analysing the Figure 9, it can be verified that at the time 15s occur simultaneous the switch off the mixer and the heater and the alarm switch on, which corresponds to the SFC specification of the controller.




Figure 6: Level tanks in function of time in normal operation of the evaporator system.




Figure 7: Switch state of the mixer, heater and alarm in normal operation of the evaporator system.




Figure 8: Level tanks in function of time with occurrence of condenser malfunction (time = 15s).




Figure 9: Switch state of the mixer, heater and alarm with occurrence of condenser malfunction (time = 15s).

It becomes still necessary, in addition to the verification that the modelling of the system obey to the SFC of the system controller, to guarantee that in the case of condenser malfunction don't occur

solidification or explosion of the solution in the tanks. Thus it is necessary taking into account the timing characteristics of the physical devices.

For example, the simulation presented in Figures 8 and 9, which values for the plant variables considered were $Q1=1$, $Q2=0.5$, $G1=G2=1$, $Ht1=Ht2=1$, $A1=0.2$ and $A2=0.05$, the obtained times for fill and empty the tank1 were, respectively, 0.6533s (limit 6s) and 2,1255s (limit 19s) and for the tank 2 respectively for fill and empty were 2,2655s (similar to the time of empty tank1) and 8,4361s (limit 26s). This simulation allowed to show that with these values of plant variables the system doesn't have serious functioning anomalies that can put in risk humans lives and material goods.

In order to obtain the relation between the plant variables and the time of the critical operations, some simulations were performed using several values of plant variables. Figure 10 and 11 show results of these simulations, respectively related to the empty tanks time (equal for the tank1 and tank2) and fill tank1 time, which correspond at the times of the critical operations of the evaporator system.




Figure 10: Empty tank time in function of plant variables.




Figure 11: Fill tank1 time in function of plant variables.

5 CONCLUSIONS

The simulation used to evaluate the plant behaviour has been developed and proposed in this paper.

The results obtained suggested that this approach is adequate to obtain the relation between the plant variables involved in the evaporator system. The present research proved to be successful using the Modelica programming Language to obtain plant models and to get functioning delays in which a property can, or not, be proved using techniques of formal verification. Moreover, the simulation techniques allow us to test different delays of the plant functioning and to see if a property, for different considered delays, is still true or if different delays imply that a property is true and after is false.

For the analysis of a system controller program it is desirable the use of simulation before using formal verification. With the simulation it is possible to eliminate a set of program errors of some possible system behaviours in reduced intervals of time. This would not happen, in most of the cases, if these errors were detected only through the use of formal verification techniques. Conciliating these two techniques the time necessary for the attainment of results through the use of the formal verification technique can be substantially reduced. With this approach a manufacturer of industrial automated systems does not need the physical part of the machine for later perform tests and simulation of the system controller. In consequence, they allow, together, to reduce the times of production of the automated systems.

ACKNOWLEDGEMENTS

This research project is carried out in the context of the SCAPS Project supported by FCT, the Portuguese Foundation for Science and Technology, and FEDER, the European regional development fund, under contract POCI/EME/61425/2004 that deals with safety control of automated production systems.

REFERENCES

- Baresi L., Mauri M., Monti A., Pezzè M., 2000. PLCTOOLS: Design, Formal Validation, and Code Generation for Programmable Controllers. *Special Session at IEEE Conference on Systems, Man, and Cybernetics*. Nashville USA.
- Baresi L., Mauri M., Pezzè M., 2002. *PLCTools: Graph Transformation Meets PLC Design*. Electronic Notes in Theoretical Computer Science 72 No. 2.
- Basu S., Pollack R., Roy M., 2006. *Algorithms in Real Algebraic Geometry - Algorithms and Computation in Mathematics*. Springer Editions, vol. 10, 2nd edition.
- David A., Behrmann G., Larsen K. G., Yi W., 2003. *A Tool Architecture for the Next Generation of UPPAAL*. Technical Report n. 2003-011, Department of Information Technology, Uppsala University, Feb. 20 pages.
- Elmqvist E., Mattson S., 1997. An Introduction to the Physical Modelling Language Modelica. *Proceedings of the 9th European Simulation Symposium, ESS'97*. Passau, Germany.
- Elmqvist, Hilding, Mattsson S., Otter M., 1999. Modelica - a language for physical system modeling, visualization and interaction. *Proceedings of the IEEE Symposium on Computer-Aided Control System Design*. August, Hawaii.
- Fritzson, Peter, Vadim E., 1998. Modelica, a general object-oriented language for continuous and discrete-event system modeling and simulation, *12th European Conference on Object-Oriented Programming (ECOOP'98)*. Brussels, Belgium.
- Fritzson, Peter, Bunus P., 2002. Modelica, a general object-oriented language for continuous and discrete-event system modelling and simulation. *Proceedings of the 35th Annual Simulation Symposium*. April, San Diego, CA.
- Huuck R., Lukoschus B., Lakhnech. Y., 2001. *Verifying Untimed and Timed Aspects of the Experimental Batch Plant*. European Journal of Control, vol. 7, n° 4, pp. 400-415.
- Kowalewski S., Stursberg O., Bauer. N., 2001. *An Experimental Batch Plant as a Test Case for the Verification of Hybrid Systems*. European Journal of Control.
- Machado J., Seabra E., Soares F., Campos J., 2007. A new Plant Modelling Approach for Formal Verification Purposes. *Submitted at 11th IFAC/IFORS/IMACS/IFIP Symposium on Large Scale Systems: Theory and Applications*. Gdansk, Poland.
- Moon I. 1994. *Modeling programmable logic controllers for logic verification*. IEEE Control Systems, 14, 2, pp. 53-59.
- Otter M., Årzén K., Dressler I., 2005 *StateGraph - A Modelica Library for Hierarchical State Machines*. Modelica 2005 Proceedings.
- Roussel M., Denis B., 2002. *Safety properties verification of ladder diagram programs*. Journal Européen des Systèmes Automatisés, vol. 36, pp. 905-917.